



# EMSL Analytical, Inc.

5221 Militia Hill Road Plymouth Meeting, PA 19462  
Tel/Fax: (610) 828-3102 / (610) 828-3122  
<http://www.EMSL.com> / [plymouthmeetinglab@emsl.com](mailto:plymouthmeetinglab@emsl.com)

EMSL Order: 182000344

Customer ID: ALIC62

Customer PO:

Project ID:

**Attention:** Christa Knorr  
Alicon Environmental, Inc.  
101 Stoney Creek Road  
Clarks Summit, PA 18411

**Phone:** (570) 563-2719

**Fax:** (570) 563-1505

**Received Date:** 02/03/2020 09:00 AM

**Analysis Date:** 02/03/2020

**Collected Date:** 02/01/2020

**Project:** SSD - West Scranton Intermediate

## Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm <sup>2</sup> )	Non Asb	Asbestos Type(s)	#Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥0.5μ < 5μ	≥5μ		(S/mm <sup>2</sup> )	(S/cc)
WSIS-01 182000344-0001	Main Lobby	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
WSIS-02 182000344-0002	Library	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
WSIS-03 182000344-0003	Gym Passageway Intersection	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
WSIS-04 182000344-0004	Ground Floor Elevator Lobby	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049

Analyst(s)

Kevin Ream (4)

Michael Thoma, Laboratory Manager  
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm<sup>3</sup> and structures/mm<sup>2</sup> are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA NVLAP Lab Code 200699-0, Philadelphia ALL-292, VA 3333000315, AIHA-LAP, LLC IHLAP #178659

Initial report from: 02/03/2020 15:11 PM